



Town of North Wilkesboro

January 06, 2009

North Wilkesboro Collection System Performance Annual Report

Contact Person: David Webb, (336) 838-4362 or
Steven McNeil, (336) 838-4362
PO Box 218 North Wilkesboro, NC 28659

Permit Numbers: WQCS00093 (1360 West D Street / PO Box 218 North Wilkesboro)

Description of System: Collection

Performance: System listed above performed as designed and had no deficiencies for 2008 to date.

Permit Limit Violations: None (January 2008 to date)

Monitoring and Reporting Violations: None (January 2008 to date).

(Illegal) By-pass of Treatment Facilities: None (January 2008 to date)

Number of Sanitary Sewer Overflows: (13) None over 1000 gallons / None that reached surface water.

Environmental Impacts: No known environmental impacts.

Description of Correction Measures: (Jetting/Cleaning, Camera System, General Maintenance & Inspections of the Collection System)

Notifications: Copy of this report will be on display for all users / customers at the North Wilkesboro Town Hall for a period of 30 days. Also there will be a copy on file at the office of supervisor of the collection system located at 801 Main Street.

Upon signing this report, I certify that all statements are true and accurate to the best of my knowledge.

Signed this 6th day of January 2009

David Webb

Water/Sewer Maintenance
Supervisor (Collection)

Steven McNeil

Back Up (Collection System)