

January 28, 2022

North Wilkesboro Wastewater System Performance Annual Report

Contact Person: Scott Perry, (336) 838-5001 or
Justin Shell, (336) 838-5001
P.O. Box 218 North Wilkesboro, NC 28659

Permit Numbers: NC0020761 (100 Thurman Street)

Description of System: Activated Sludge

Performance: System listed above performed as designed and had no deficiencies for January 2021 to date.

Permit Limit Violations: One. Due to heavy rain from Tropical Storm Fred we did not meet our limits on Fecal Coliform for August seventeenth and eighteenth.

Monitoring and Reporting Violations: None (January 2021 to date)

(Illegal) By-pass of Treatment Facilities: None (January 2021 to date)

Sanitary Sewer Overflows: None



Environmental Impacts: No known environmental impacts.

Description of Correction Measures: (No need for correction measures from January 2021 to date because there were no violations or deficiencies.)

Notifications: Copy of this report will be on display for all users / customers at the North Wilkesboro Town Hall for a period of 30 days. Also there will be a copy on file at the North Wilkesboro Wastewater Plant located at 100 Thurman Street.

Upon signing this report, I certify that all statements are true and accurate to the best of my knowledge.

Signed this 28th day of January 2022

 , ORC
 , CPO